

February 2014 report for the Old Orchard Beach Wastewater Department

Generated by Chris White, Wastewater Superintendent

Process control

Monthly totals:

- Discharged 20.8 million gallons of treated wastewater
- Produced (dewatered) and disposed of 23 tons of bio-solids
- Removed 88% of the suspended solids in the wastewater stream
- Removed 89% of biological oxygen demand (biological activity)

Alarms and call outs

- 2/5 – West Grand low wet well level

Activities

- First quarter analytical chemistry testing completed
- Hazard assessment and job safety assessments 90% complete
- Snow removal for four (4) snowstorms
- West Grand pump station channel grinder rebuilt and installed by OOBWW staff
- All minor preventative services performed on the emergency generators
- Put secondary clarifier #2 on line
- Chlorine contact chambers cleaned
- Performed oil changes in five pumps in the Process Building
- Repaired John Deere tractor snow blower attachment
- Congratulations to Mike Hersey for completing 20 years of service to the town of Old Orchard Beach!

This concludes the February 2014 report for the OOBWW Department

Filename: Monthly report February 2014.docx
Directory: C:\Users\tlambert\AppData\Local\Microsoft\Windows\Temporary
Internet Files
Template: C:\Users\tlambert\AppData\Roaming\Microsoft\Templates\Normal.dot
m
Title:
Subject:
Author: Chris White
Keywords:
Comments:
Creation Date: 3/13/2014 3:10:00 PM
Change Number: 4
Last Saved On: 3/13/2014 3:11:00 PM
Last Saved By: Chris White
Total Editing Time: 5 Minutes
Last Printed On: 3/14/2014 9:42:00 AM
As of Last Complete Printing
Number of Pages: 2
Number of Words: 168 (approx.)
Number of Characters: 962 (approx.)