

November 2013 report for the Old Orchard Beach Wastewater Department

Generated by Chris White, Wastewater Superintendent

Process control

Monthly totals:

- Discharged 18.4 million gallons of treated wastewater
- Produced (dewatered) and disposed of 100 tons of bio-solids
- Removed 96.0% of the suspended solids in the wastewater stream
- Removed 94.9% of biological oxygen demand (biological activity)

Alarms and call outs

- On 11/15 - high wet well level at West grand pump station
- On 11/24 – low wet well for the Effluent pump station
- On 11/30 – two alarms for a low chlorine level

Replaced the inline dissolved oxygen equipment at the wastewater facility

Replaced concrete steps at the effluent pump station

Drained, cleaned and inspected the #2 secondary clarifier

Placed the #1 secondary clarifier on line

Started OOB Wastewater Association negotiations

Prepared the sander and plow equipment for winter

Winterized summer equipment

This concludes the October 2013 report for the OOBWW Department

Filename: WWTP November 2013.docx
Directory: \\Store01\users\tlambert\MONTHLY REPORTS
Template: C:\Users\tlambert\AppData\Roaming\Microsoft\Templates\Normal.dot
m
Title:
Subject:
Author: Chris White
Keywords:
Comments:
Creation Date: 12/20/2013 8:35:00 AM
Change Number: 2
Last Saved On: 12/20/2013 8:35:00 AM
Last Saved By: Tammy Lambert
Total Editing Time: 0 Minutes
Last Printed On: 1/23/2014 11:26:00 AM
As of Last Complete Printing
Number of Pages: 2
Number of Words: 152 (approx.)
Number of Characters: 873 (approx.)