

October 2013 report for the Old Orchard Beach Wastewater Department

Generated by Chris White, Wastewater Superintendent

Process control

Monthly totals:

- Discharged 22.3 million gallons of treated wastewater
- Produced (dewatered) and disposed of 98 tons of bio-solids
- Removed 97.9% of the suspended solids in the wastewater stream
- Removed 96.1% of biological oxygen demand (biological activity)

Alarms and call outs

- On 10/1 an Effluent pump station alarm was received
- On 10/16 a low level alarm for Dune Grass 200 pump station was received

Set up lock out tag out station

Completed the filing and indexing of all safety data sheets

Pumped down marsh when the Goosefare outlet was blocked from October 2-10

Purchased the Idexx Quanti-Tray for performing fecal testing

Completed asset and computer inventory lists

Completed mandatory fire extinguisher training

Closed the down town fountain and sent proceeds to the Community Animal Watch

DEP inspection on 10/17

Completed all fall tank and wetwell cleanings

This concludes the October 2013 report for the OOBWW Department

Page 1

Filename: Monthly report October
Directory: C:\Users\tlambert\AppData\Local\Microsoft\Windows\Temporary
Internet Files
Template: C:\Users\tlambert\AppData\Roaming\Microsoft\Templates\Normal.dot
m
Title:
Subject:
Author: Chris White
Keywords:
Comments:
Creation Date: 11/12/2013 10:02:00 AM
Change Number: 4
Last Saved On: 11/12/2013 3:25:00 PM
Last Saved By: Chris White
Total Editing Time: 302 Minutes
Last Printed On: 11/13/2013 2:10:00 PM
As of Last Complete Printing
Number of Pages: 2
Number of Words: 164 (approx.)
Number of Characters: 940 (approx.)